

Indicating Valves, Butterfly or Ball Type

Design features provide a dependable visible indication of the open position even at a distance. If excessive force is applied to the handle, weakness-joints will break so as to preserve correct orientation between indicator and valve position. Valve and indicator parts are so designed that they can be assembled only one way, always to give correct indication. All FM Approved indicating valves turn clockwise to shut. They are small, lightweight, and, because of a resilient seat, are easy to operate. They are not subject to sticking or dropped gates. They are not recommended for throttling service. Unless otherwise noted in the listing, these valves have 175 psi (1205 kPa) rated working pressure.

Model Nos. NIBV-G, NIBV-W, NIBB-T, NIBB-G, NIBO-G 300, NIBO-W 300, NIHPBO-W

Model Number	Product Type	Nominal Pipe Size, mm	Rated Working Pressure, psi (kPa)	Remarks
NIBV-G	Butterfly Valve, Grooved Ends	2 ½, 3, 4, 5, 6, 8 (65, 80, 100, 125, 150, 200)	175 (1205)	a, c, d
NIBV-W	Butterfly Valve, Wafer Body	2 ½, 3, 4, 5, 6, 8 (65, 80, 100, 125, 150, 200)	175 (1205)	a, c, d
NIBB-T	Butterfly Valve, Threaded Ends	1, 1 ¼, 1 ½, 2, 2 ½ (25, 32, 40, 50, 65)	175 (1205)	a, c, d
NIBB-G	Butterfly Valve, Grooved Ends	2, 2 ½ (50, 65)	175 (1205)	a, c, d
NIBO-G 300	Butterfly Valve, Grooved Ends	2 ½, 3, 4, 5, 6, 8 (65, 80, 100, 125, 150, 200)	300 (2070)	a, b, c
NIBO-W 300	Butterfly Valve, Wafer Body	2 ½, 3, 4, 5, 6, 8 (65, 80, 100, 125, 150, 200)	300 (2070)	a, b, c
NIHPBO-W	Butterfly Valve, Wafer Body	2 ½, 3, 4, 5, 6, 8 (65, 80, 100, 125, 150, 200)	300 (2070)	a, b, c

Remarks:

- a. Available with dual supervisory switches.
- b. FM Approved for indoor and outdoor use.
- c. FM Approved for aboveground installations only.
- d. FM Approved indoor service only.

Company Name:	NewAge Fire Protection Industries Pvt. Ltd
Company Address:	4, Champaklal Udyog Bhavan, Sion (east), Mumbai-22 - 400 022 , India
Company Website:	http://www.newagefireprotection.com
New/Updated Product Listing:	Yes
Listing Country:	India
Certification Type:	FM Approved